



## **Fire Alarm Design Requirements**

Summit Mall – Akron, OH

Bulletin Updated:  
05.24.16

Each Tenant space must install a standalone fire alarm panel and must be compatible with Landlord's panel. Panels should be equipped with a digital readout.

Each space shall have a minimum of two (2) smoke detectors and two (2) audio/visual devices. These devices should be placed at the back of house and sales floor. Additional devices are at the discretion of the fire department.

Duct detectors are to be powered by the standalone fire panel and be programmed as a 'supervisory' alarm.

Design and installation drawings must be submitted to Summit County Building Department and the Fairlawn Fire Department for review and permit.

Tenant is required to use Landlord's contractor, Simplex Grinnell, to connect to Landlord's panel.