



## Temperature Controls Bulletin

### Chilled Water

SouthPark

#### **HVAC Controls:**

- Tenant's HVAC System will be required to interface with the Landlord's Energy Management System.
- Tenant shall provide the required 2-way modulating control valves for the unit(s) cooling coil(s).
- Tenants will need to provide a BACnet/IP controller. If a BACnet MS/TP controller is used then they will need to add an MS/TP to IP router from KMC, part number BAC-5051E. Data sheet will be provided with the Property Rule & Regulation documents.
- Coordinate all HVAC control requirements with the Mall Operations Director.