

# **Penn Square Bulletin #1**

## **Rooftop HVAC Unit Curb Requirement**

**Penn Square is in the process of a multi-year, phased roof replacement with tapered insulation. The new roofing system will require higher than normal curbs for rooftop HVAC units.**

**All new rooftop HVAC units installed at this center will need to be set on a 20” high curb. The new curbs must be factory manufactured. Curb adapters will not be permitted.**